

Technical Compliance Statement

Ref. No.: ACWE-RC170143 (ACWE-C1W1704041)

For the following equipment

Applicant : SMA New Energy Technology(Jiangsu)Co.,Ltd
Manufacturer : SMA New Energy Technology(Jiangsu)Co.,Ltd
Product : PV inverter
Model Number : (1) Evershine TLC4000
(2) Evershine TLC5000
(3) Evershine TLC6000
Brand : zerversolar

We, **AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.** hereby certify that the above product has been tested by us with the listed standards and found in compliance with the council EMC directive 2014/30/EU. The test data & results are issued on the EMC test report No. **ACWE-E1303002B**.

Emission: EN 61000-6-3:2007+A1:2011+AC:2012; EN 61000-6-4:2007+A1:2011
EN 61000-3-2:2014, EN 61000-3-3:2013

Immunity: EN 61000-6-1:2007; EN 61000-6-2:2005
(IEC 61000-4-2:2008, IEC 61000-4-3:2006+A2:2010,
IEC 61000-4-4:2012, IEC 61000-4-5:2014,
IEC 61000-4-6:2013, IEC 61000-4-8:2009, IEC 61000-4-11:2004)

Jul.12, 2017



Ken Lu/ Assistant General Manager
AUDIX Technology (Wujiang) Co., Ltd. EMC Dept.



The statement is based on a single evaluation of one sample of the above-mentioned product. It does not imply an assessment of the whole production and does not permit the use of the test lab logo.