

# Zertifikat

# Certificate



Zertifikat Nr. *Certificate No.*  
PV 60136267

Blatt *Sheet*  
0004

Ihr Zeichen *Client Reference*

Unser Zeichen *Our Reference*

Ausstellungsdatum

*Date of Issue*

0001--21290484 003

10.06.2020

(day/mo/yr)


Genehmigungsinhaber *License Holder*

Mundra Solar PV Limited  
Survey No 180 P & others,  
Tunda, Mundra  
Dist: Kutch 370421  
India

Fertigungsstätte *Manufacturing Plant*

Mundra Solar PV Limited  
Survey No 180 P & others,  
Tunda, Mundra  
Dist: Kutch 370421  
India

Prüfzeichen *Test Mark*



IEC 61215  
IEC 61730  
Regular Production  
Surveillance  
[www.tuv.com](http://www.tuv.com)  
ID 1111217704

Geprüft nach *Tested acc. to*

IEC 61215-1:2016  
IEC 61215-1-1:2016  
IEC 61215-2:2016  
IEC 61730-1:2016  
IEC 61730-2:2016

Zertifiziertes Produkt (Geräteidentifikation)

*Certified Product (Product Identification)*

Lizenzentgelte - Einheit

*License Fee - Unit*

PV Module

Type:

with 6" poly cells  
ASP-7-AAA (AAA = 315-350 in steps of 1, 72 cells)

with 6" mono cells

ASM-7-PERC-AAA (AAA = 340-385 in steps of 1, 72 cells)  
AAA represents output power in Wp

Remarks:

Max. System Voltage: 1500 VDC (Voc at STC)  
Class II acc. to IEC 61140  
Max. positive Design Load (downward): 3600 Pa  
Max. negative Design Load (upward): 1600 Pa  
tested with safety factor 1.5  
Additional applicable test standards see page 2.

Conditions:

The product test is voluntarily according to technical regulations. Any change of the design, materials, components or processing may require the repetition of some of the qualification tests in order to retain type approval.  
Validity: 31 January 2024

*Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.  
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.  
This certificate is based on our Testing and Certification Regulation. The product fulfills above mentioned requirements, the production is subject to surveillance.*

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: [cert-validity@de.tuv.com](mailto:cert-validity@de.tuv.com)  
Fax: +49 221 806-3935 <http://www.tuv.com/safety>



Dipl.-Ing. G. Cox